



DISABILITY AND COMMUNICATION ACCESS BOARD

919 Ala Moana Boulevard, Room 101 • Honolulu, Hawaii 96814
Ph. (808) 586-8121 (V/TDD) • Fax (808) 586-8129

INTERPRETIVE OPINION

Pursuant to §103-50, Hawaii Revised Statutes (HRS), all buildings and facilities constructed by, or on behalf of the State or any county, shall conform to the Americans with Disabilities Act Accessibility Guidelines (ADAAG) and amendments. In accordance to HRS §103-50 and Chapter 11-217, Hawaii Administrative Rules, the Disability and Communication Access Board has authority to issue interpretive opinions to HRS §103-50 design standards.

Docket: **DCAB 2005-03:** Can a 30 inch by 60 inch minimum shower stall, which is required to comply with RHAG 13.3.5 Showers, have a fixed, folding type seat, which is mounted on the wall adjacent to the controls as shown in ADAAG Fig. 57?

Ruling: For buildings or facilities subject to HRS §103-50,

RHAG 13.3.5(5) Showers.

A 30 inch by 60 inch minimum roll-in shower stall which is required to comply with the RHAG Section 13.3.5 (5) Showers, may have a fixed, folding type seat, which is mounted on the wall adjacent to the controls as required in the ADAAG Section 4.21.3 and as shown in Fig. 57.

[Rul: 07/05] (Auth and Imp: HRS §103-50)

If you have any questions or comments regarding this ruling, please call us at 586-8121.

DISABILITY AND COMMUNICATION ACCESS BOARD